

FIRE BARRIER ASSEMBLY INSTRUCTIONS

1. Fire barrier element is premounted on a straight element or elbow of Isolsbarra.
2. The fire barrier is recognisable by a red label on the external part of the element.
3. The fire barrier must be placed inside the wall / ceiling.
4. The position is correct when the red label is all inside the wall.
5. When the element is inside the wall, the empty space around it must be filled by concrete or fire resistant material (not supplied by Graziadio)
6. The aluminium cover allows the use of almost all the filling materials (cement, rock wool, polyurethane foams, etc).
7. Before energise, make an insulation test as prescribed by IEC standard.

